



A, L, H, X部寸法許容差	
呼び径mm	許容差mm
6.35以上 9.53以下	±1.0
12.70以上19.05以下	±1.1
22.23以上	±1.2

品番	接続管	各部寸法				
		I.Dφa	L	X	B	t(min)
S-1	6.35	6.43+0.08-0	15	0.8	7.10	0.6
S-2	7.94	8.10+0.06-0.04	17	0.8	8.10	0.6
S-3	9.52	9.62+0.03-0.04	19	0.8	9.10	0.6
S-4	10.00	10.10+0.03-0.05	20	0.8	9.60	0.6
S-5	12.70	12.85+0.03-0.05	22	1.0	10.50	0.7
S-6	15.88	16.00+0.03-0.07	25	1.0	12.00	0.8
S-7	19.05	19.19+0.08-0.09	30	1.0	14.50	0.8
S-8	22.23	22.36+0.08-0.09	34	1.0	16.50	0.9
S-9	25.40	25.55+0.12-0	40	1.0	19.50	0.9
S-10	28.58	28.75+0.04-0.10	43	1.0	21.00	1.0
S-11	31.75	31.83+0.15-0	48	2.5	22.75	1.0
S-12	34.93	35.11+0.04-0.12	51	1.0	25.00	1.2
S-13	38.10	38.30+0.16-0	53	1.0	26.00	1.2
S-14	41.27	41.50+0.05-0.14	58	1.0	28.00	1.3
S-15	44.45	44.55+0.20-0	61	2.0	29.50	1.4
S-16	50.80	51.00+0.20-0	68	2.0	33.00	1.4
S-17	53.98	54.22+0.16-0.16	70	2.0	34.00	1.5
S-19	66.68	66.96+0.20-0.20	78	2.0	38.00	1.7
S-21	79.38	79.66+0.20-0.25	85	2.0	41.50	2.0

※寸法許容差は実測内径及び平均による。

名称	ソケット	寸法				
図番		材質	JIS H3300 C1220			
納入先		備考				
①			作成年月日		第三角法	
②			2001年 9月 26日		尺度 /	
③			承認	検図	設計	製図
④						
⑤			株式会社ダイトー			
⑥						

